
Type sheet

Deflagration and endurance burning proof pressure and vacuum relief valve **KITO**® **VD/MC-IIB1-...**



Application

As an end-of-line flame arrester element to protect vent openings of storage tanks. Explosion and endurance burning proof for all inflammable liquids and vapors of explosion group IIB1 and also for alcohols with a maximum experimental safe gap (MESG) \geq 0.85 mm and an maximum operating temperature of 60 °C. This device is not permitted to be installed in enclosed areas. Installation on top of storage tanks, tank access covers or breather pipes. As venting and breather device for fixed roof tanks to prevent inadmissible pressure and vacuum and to minimize gas losses by variable pressure setting of the weight-loaded valve devices. An explosion proof condensate drain is also available for this model at extra cost.

KITO® BEH-3-80-IIB1 with additional examination and approval, applicable also for alcohols (ethanol, methanol...)

Dimensions (mm) and settings (mbar) Deflagration and endurance burning professed that filter arrester – End-of-line deflagration filter arrester endurance burning professed drain filter arrester – End-of-line deflagration filter arrester endurance burning professed drain filter arrester endurance burning professed drain filter arrester endurance burning professed drain filter arrester – End-of-line deflagration filter arrester endurance burning professed drain filter arrester – End-of-line deflagration filter arrester endurance burning professed drain filter arrester – End-of-line deflagration filter arrester endurance burning professed drain filter arrester – End-of-line deflagration filter arrester –

DN		D	н	number of KITO [®] BEH-3-	setting		
					vacuum	pressure	kg
DIN	ASME			80-IIB1	min max.	min max.	
80 PN 16	3"	855	615	2	3.3 - 60	1.8 - 100	60
100 PN 16	4"	950	645	3	2.5 - 70	1.7 - 100	110
125 PN 16	5"						
150 PN 16	6"	1110	650	4	3.5 - 60	2.5 – 110	
200 PN 10	8"	1470	795	6	2.9 – 65	2.1 - 105	235

Indicated weights are understood without weight load and refer to the standard design Higher settings on request!

Example for order

KITO® VD/MC-IIB1-80

(design DN 80 with flange connection DN 80 PN 16)

Type examination certificate to EN ISO 16852 and Certificate to EN ISO 16852 and Certificate to ATEX-Directive 2014/34/EU for KITO[®] BEH-3-80-IIB1 and KITO[®] SK/K-IIB1

page 1 of 2

E 16.9.1 N 08-2018

Created: Abt. Doku KITO


Design subject to change

Date:



Type sheet

Deflagration and endurance burning proof pressure and vacuum relief valve KITO® VD/MC-IIB1-...



Design


	standard	optionally		
housing	steel	stainless steel mat. no. 1.4571		
housing KITO® BEH-3-80-IIB1	cast steel mat. no. 1.0619	stainless cast steel mat. no. 1.4408		
gasket	HD 3822	PTFE		
design valve pallet	orifice plate			
valve seat, valve spindle	stainless steel mat. no. 1.4571			
load weight	stainless steel mat. no. 1.4571	PE		
valve sealing	NBR	Viton, PTFE, EPDM, metal sealing		
	≥ 100 mbar only PTFE or metal sealing			
KITO®-flame arrester element	completely interchangeable			
KITO®-casing / KITO®-grid	stainless steel mat. no. 1.4408 / 1.4310	stainless steel mat. no. 1.4408 / 1.4571		
weather hood	PMMA			
protective screen	PA6			
flange connection	EN 1092-1 type B1	ASME B16.5 Class 150 RF		


Performance curves

Flow capacity V based on air of a density ρ = 1.29 kg/m³ at T = 273 K and atmospheric pressure p = 1.013 mbar. For other gases the flow can be approximately calculated by

$$\dot{V}_{40\%} = \dot{V}_{b} \cdot \sqrt{\frac{\rho_{b}}{1.29}}$$
 or $\dot{V}_{b} = \dot{V}_{40\%} \cdot \sqrt{\frac{1.29}{\rho_{b}}}$

The indicated flow rates will be reached by an accumulation of 40% above valve's setting (see DIN 4119). If the allowable overpressure is less 40%, please consult der factory for the corrected volume flow.





page 2 of 2

KITO Armaturen GmbH Grotrian-Steinweg-Str. 1c D-38112 Braunschweig VAT Reg.No DE812887561 +49 (0) 531 23000-0 +49 (0) 531 23000-10

www.kito.de info@kito.de

E 16.9.1 N
Date: 08-2018

Created: Abt. Doku KITO

Design subject to change